



CITY OF SAINT PAUL

Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220  
Saint Paul, MN 55101-1806

Telephone: 651-266-8989  
Facsimile: 651-266-9124  
[www.stpaul.gov/dsi](http://www.stpaul.gov/dsi)

## Code Compliance Report

May 04, 2016

**\* \* This Report must be Posted  
on the Job Site \* \***

RAMSEY COUNTY PROPERTY RECORDS  
90 PLATO BLVD W  
ST PAUL MN 55107

Re: 614 Edmund Ave  
File#: 09 043876 VB2

Dear Property Owner:

The following is the Code Compliance report you requested on March 24, 2016.

Please be advised that this report is accurate and correct as of the date May 04, 2016. All deficiencies identified by the City after this date must also be corrected and all codes and ordinances must be complied with. This report is valid for 365 days from May 04, 2016. This report may be used in lieu of a Truth in Housing Report required in St Paul Legislative Code 189. This building must be properly secured and the property maintained at all times.

In order to sell or reoccupy this property the following deficiencies must be corrected. A Legislative Code exemption (Chapter 33.03(f)) allows a Category 2 Vacant Building to be sold "as is" providing the buyer, prior to closing, completes an approval process. For further information, call Reid Soley at 651-266-9120.

### ZONING

1. This property is in a(n) T2 zoning district.
2. The property was inspected as a Duplex.

BUILDING Inspector: Jim Seeger

Phone: 651-266-9046

1. Insure basement cellar floor is even, is cleanable, and all holes are filled. SPLC 34.10 (1)
2. Provide complete storms and screens, in good repair for all door and window openings. SPLC 34.09 (3e)
3. Provide functional hardware at all doors and windows. SPLC 34.09 (3f)
4. Exit doors shall be capable of being opened from the inside, easily and without the use of a key. Remove all surface bolts. SPLC 34.09 (3h)

5. Repair or replace damaged doors and frames as necessary, including storm doors. SPLC 34.09 (3f)
6. Weather seal exterior doors, threshold and weather-stripping. SPLC 34.09 (3f)
7. Install floor covering in bathroom and kitchen that is impervious to water. SPLC 34.10 (4)
8. Repair walls, ceiling and floors throughout, as necessary. SPLC 34.34 (6)
9. Prepare and paint interior and exterior as necessary. Observe necessary abatement procedures (EPA, MPCA and St. Paul Legislative Code, Chapter 34 for additional information) if lead base paint is present. SPLC 34.33 (1)
10. Any framing members that required repair or do not meet code (where wall and ceiling covering is removed, members that are over-spanned, over-spaced, not being carried properly, door and window openings that are not adequately supported, etc.) are to be reconstructed in an approved manner. SPLC 34.34 (1)
11. Provide fire block construction as necessary and seal chases in basement ceiling. MNRC Ch 1309 Sect. 602.8
12. Tuck Point interior/exterior of foundation as necessary. SPLC 34.09 (1)
13. Where wall and ceiling covering is removed install full thickness or code-specified insulation. MN Energy Code Ch. 1322.1101 (except. 4)
14. Air-seal and insulate attic/access door. MN Energy Code Ch 1322.1102.4
15. Install Smoke Detectors/Carbon Monoxide Detectors per MN Conservation Code and the MN Dept. of Labor and Industry: Install per code where feasible. MNRC Ch 1309 Sect 313.2.1
16. Provide major clean-up of premises. SPLC 34.34 (4)
17. Install water-proof enclosure in shower area. MNRC Ch 1309 Sect. 307
18. Provide weather sealed, air sealed and vermin sealed exterior. SPLC 34.32 (2)
19. Repair siding, soffit, fascia, trim, etc. as necessary. SPLC 34.09 (1)
20. Provide proper drainage around house to direct water away from foundation of house. SPLC 34.08 (2)
21. Provide proper drainage around house to direct water away from foundation of garage. SPLC 34.08 (2)
22. Install downspouts and a complete gutter system. SPLC 34.33 (1d)
23. Dry out basement and eliminate source of moisture. SPLC 34.10 (10)
24. Install rain leaders to direct drainage away from foundation. SPLC 34.33 (1d)
25. Provide general rehabilitation of garage. SPLC 34.32 (3)
26. Install address numbers visible from street and on the alley side of garage. SPLC 70.01
27. Provide ground cover capable of controlling sediment and erosion. SPLC 34.08 (3)
28. Remove trees which are against foundation of home and garage. SPLC 34.09 (1b)
29. Remove mold, mildew and moldy or water damaged materials. SPLC 34.10 (1)
30. Install 20 minute fire rated doors, with self closing device, between common areas and individual units. All penetrations required to have property intumescent device or caulk (per current building codes). MNRC Ch 1309 Sect.

317

31. Maintain one hour fire separation between dwelling units and between units and common areas. MNRC Ch 1309 Sect. 317
32. Install handrails (34 inches - 38 inches above each nosing) and guardrails (36 inch minimum) at all stairways, and return hand rail ends into a newel post or wall per attachment. MNRC Ch 1309 Sect. 311 & 312
33. Strap or support top of stair stringers for structural stability. MNRC Ch 1309 Sect 311.1
34. Repair or Replace any deteriorated window sash, broken glass, sash holders, re-putty, etc as necessary. SPLC 34.09 (3)
35. A building permit is required to correct the above deficiencies. All work is to be done in a workmanship like manner. SPLC 33.03 (a)

ELECTRICAL Inspector: Dave Blank

Phone: 651-266-9035

---

1. Properly wire electric water heater to current NEC (2nd floor).
2. Repair damaged electrical due to vandalism to current NEC.
3. Properly wire 1st floor bathroom lighting.
4. Replace meter socket and service conduits.
5. Perform a service load calculation to ensure adequate ampacity.
6. No power at time of inspection. Test all electrical outlets and ensure all luminaires (light fixtures) are working properly when power is restored.
7. Repair the electrical service grounding conductor to the metallic water piping system. Install a conductor sized to Table 250.66 (NEC) from the electrical service to within 5' of the entrance point of the water service, and bond around the water meter. Article 250, NEC
8. Provide a complete circuit directory at service panel indicating location and use of all circuits. Article 408.4, NEC
9. Repair or replace all broken, painted over, corroded, missing or loose receptacles, luminaires (light fixtures), switches, covers and plates to current code. Article 406.4(D) & Article 410, NEC (painted receptacles - (4) 2nd floor North bedroom, (1) 2nd floor living room, (3) 1st floor living room, (2) 1st floor North bedroom, (3) 1st floor West bedroom, (3) 1st floor kitchen, (5) 1st floor SE bedroom).
10. Check all receptacles for proper polarity (including 2-prong) and verify ground on 3-prong receptacles. Ensure all GFCI receptacles are functioning properly. Rewire and/or replace receptacles that are improperly wired or not functioning properly. Article 406.4(D), NEC
11. Install hard-wired, battery backup, Carbon Monoxide smoke detector as specified in Chapter 58 of the Saint Paul Legislative Code, and other smoke detectors and carbon monoxide detectors as required by the Minnesota State Building Code. SPLC 58, IRC
12. Replace electrical service panel due to excessive corrosion, contaminants, and vandalism Article 110.12 (B), NEC
13. Replace conduit/fittings due to excessive corrosion. Article 110.12 (B), NEC

14. All electrical work must be done by a Minnesota-licensed electrical contractor under an electrical permit.

PLUMBING Inspector: Karl Abrahamson

Phone: 651-266-9049

---

1. Gas Piping -(MFGC 402) Install piping and fittings with the proper sizing.
2. Lawn Hydrants -(MPC 301.1) Repair or replace the lawn hydrants that are broken or have parts missing.
3. Lawn Hydrants -(MPC 603.5.7) The lawn hydrant(s) require a backflow preventer.
4. Piping Vents -(MPC 904 & 906.7) Install the correct size piping vents.
5. Plumbing - General -(MPC 402.2) Provide a water tight joint between the fixture and the wall or floor.
6. Basement -Gas Piping -(MMC 103) Replace corroded gas piping/fittings.
7. Basement -Gas Piping -(MFGC 411) Install an approved shut off; connector and gas piping for the dryer.
8. Basement -Gas Piping -(MFGC 614.1-614.7) Vent clothes dryer to code.
9. Basement -Gas Piping -(MFGC 406.4.1) Conduct a witnessed pressure test on gas piping system.
10. Basement -Gas Piping -(MMC 103) Remove all disconnected gas lines and unapproved valves.
11. Basement -Laundry Tub -(MPC .0100 & 901) Install a proper fixture vent to code.
12. Basement -Laundry Tub -(MPC 701) Install the waste piping to code.
13. Basement -Laundry Tub -(MPC 301.1) Repair/replace the fixture that is missing, broken or has parts missing.
14. Basement -Laundry Tub -(MPC 301.1) Repair/replace the faucet that is missing, broken or has parts missing.
15. Basement -Soil and Waste Piping -(MPC 709.1) Install a front sewer clean out.
16. Basement -Soil and Waste Piping -(MPC 704 & 706) Replace all improper connections, transitions, fittings or pipe usage.
17. Basement -Water Heater -(MFGC 409) Install the gas shut off and the gas piping to code.
18. Basement -Water Heater -(MFGC 503) Install the water heater gas venting to code.
19. Basement -Water Heater -(MFGC 501.12) The water heater venting requires a chimney liner.
20. Basement -Water Heater -(MPC 501)Install the water piping for the water heater to code.
21. Basement -Water Heater -(MPC .0100 Q)The water heater must be fired and in service.
22. Basement -Water Heater -(MMC 701) Provide adequate combustion air for the gas burning appliance.
23. Basement -Water Meter -(MPC 609.11 & SPRW Sec. 904.04 (a))Raise the water meter to a minimum of 12 inches above the floor.

24. Basement -Water Meter -(MPC 609.11) Support the water meter to code.
25. Basement -Water Meter -(MPC 606.2) The service valves must be functional and installed to code.
26. Basement -Water Piping -(MPC .0100 P & Q) Provide water piping to all fixtures and appliances.
27. Basement -Water Piping -(SPRWS 93.07) Provide a one (1) inch water line to the first major take off.
28. Basement -Water Piping -(MPC 313) Add the appropriate water pipe hangers.
29. Basement -Water Piping -(MPC 301.1 (3))Repair or replace all the corroded, broken, or leaking water piping.
30. First Floor -Gas Piping -(MFGC 411) Install an approved shut off; connector and gas piping for the range.
31. First Floor -Lavatory -(MPC .0100 E & 901) Install a proper fixture vent to code.
32. First Floor -Lavatory -(MPC 701) Install the waste piping to code.
33. First Floor -Lavatory -(MPC .0100 P & Q & 419.2) Install the water piping to code.
34. First Floor -Lavatory -(MPC 301.1) Repair/replace the fixture that is missing, broken or has parts missing.
35. First Floor -Lavatory -(MPC 0200 P) Repair/replace the faucet that is missing, broken or has parts missing.
36. First Floor -Lavatory -(MPC .0100 B) Provide the proper potable water protection for the faucet spout.
37. First Floor -Sink -(MPC .0100 E & 901) Install a proper fixture vent to code.
38. First Floor -Sink -(MPC 701) Install the waste piping to code.
39. First Floor -Sink -(MPC .0100 P & Q & 419.2) Install the water piping to code.
40. First Floor -Sink -(MPC 301.1) Repair/replace the fixture that is missing, broken or has parts missing.
41. First Floor -Sink -(MPC 301.1) Repair/replace the faucet that is missing, broken or has parts missing.
42. First Floor -Sink -(MPC .0100 B) Provide the proper potable water protection for the faucet spout.
43. First Floor -Toilet Facilities -(MPC .0100 E & 901) Install a proper fixture vent to code.
44. First Floor -Toilet Facilities -(MPC 701) Install the waste piping to code.
45. First Floor -Toilet Facilities -(MPC .0100 P & Q & 419.2) Install the water piping to code.
46. First Floor -Toilet Facilities -(MPC 301.1) Repair/replace the fixture that is missing, broken or has parts missing.
47. First Floor -Toilet Facilities -(MPC 301.1) Repair/replace the faucet that is missing, broken or has parts missing.
48. Second Floor -Gas Piping -(MFGC 411) Install an approved shut off; connector and gas piping for the range.
49. Second Floor -Lavatory -(MPC .0100 E & 901) Install a proper fixture vent to code.
50. Second Floor -Lavatory -(MPC 701) Install the waste piping to code.

51. Second Floor -Lavatory -(MPC .0100 P & Q & 419.2) Install the water piping to code.
52. Second Floor -Lavatory -(MPC 301.1) Repair/replace the fixture that is missing, broken or has parts missing.
53. Second Floor -Lavatory -(MPC 0200 P) Repair/replace the faucet that is missing, broken or has parts missing.
54. Second Floor -Sink -(MPC .0100 E & 901) Install a proper fixture vent to code.
55. Second Floor -Sink -(MPC 701) Install the waste piping to code.
56. Second Floor -Sink -(MPC .0100 P & Q & 419.2) Install the water piping to code.
57. Second Floor -Sink -(MPC 301.1) Repair/replace the fixture that is missing, broken or has parts missing.
58. Second Floor -Sink -(MPC 301.1) Repair/replace the faucet that is missing, broken or has parts missing.
59. Second Floor -Sink -(MPC .0100 B) Provide the proper potable water protection for the faucet spout.
60. Second Floor -Tub and Shower -(MPC .0100 E & 901)Install a proper fixture vent to code.
61. Second Floor -Tub and Shower -(MPC 701) Install the waste piping to code.
62. Second Floor -Tub and Shower -(MPC .0100 P & Q & 419.2) Install the water piping to code.
63. Second Floor -Tub and Shower -(MPC 301.1) Repair/replace the fixture that is missing, broken or has parts missing.
64. Second Floor -Tub and Shower -(MPC 301.1) Repair/replace the faucet that is missing, broken or has parts missing.
65. Second Floor -Tub and Shower -(MPC 408.3) Install scald and thermal shock protection, ASSE Standard 1016.
66. All the above corrections to waste, vent, water, and gas piping shall be per the Minnesota Plumbing Code Chapter 4714, Minnesota Rules Chapter 326, 4716, 1300, the Minnesota Mechanical Code, the Minnesota Fuel Gas Code, and Saint Paul Regional Water Services Water Code. All plumbing must be done by a plumbing contractor licensed in the State of Minnesota and the City of St. Paul by a plumber licensed in the State of Minnesota who also possess a City of Saint Paul Competency Card and after obtaining an approved City of Saint Paul Plumbing Permit.

Heating Inspector: Christi Dick

Phone: 651-266-9045

---

1. Install approved level handle manual gas shutoff valve on furnace/boiler and remove unapproved valve
2. Install approved automatic gas valve for furnace/boiler
3. Clean and Orsat test furnace/boiler burner. Check all controls for proper operation. Check furnace heat exchanger for leak; provide documentation from a licensed contractor that the heating unit is safe
4. Provide a means of returning air from every habitable room to the furnace. Return air can not be taken from closets, bathrooms, toilet rooms, kitchen or

mechanical rooms.

5. Install approved metal chimney liner
6. Replace furnace/boiler flue venting to code
7. Connect furnace/boiler and water heater venting into chimney liner
8. Provide adequate clearance from flue vent pipe on furnace/boiler to combustible materials or provide approved shielding according to code
9. Vent clothes dryer to code and provide approved gas piping and valve (plumbing or mechanical gas permit is required).
10. Provide adequate combustion air and support duct to code
11. Provide support for gas lines to code
12. Plug, cap and/or remove all disconnected gas lines
13. Provide all supply and return ducts for warm air heating system must be clean before final approval for occupancy. Documentation is required from a licensed duct-cleaning contractor that the duct system has been cleaned.
14. Repair and/or replace heating registers as necessary
15. Provide heat in every habitable room and bathrooms
16. Mechanical Gas permits are required for the above work.
17. Bathrooms require a means to ventilate the space. Provide a window with an aggregate glazing area of not less than 3 square feet, one half of which must be operable. Alternative is a bath fan properly vented to the outside. All kitchen exhaust must be venting to exterior. A mechanical ventilation permit will be required for the bath fan and/or kitchen exhaust.

Notes:

---

1. See attachment for permit requirements and appeals procedure.
2. Provide plans and specifications for any portion of the building that is to be rebuilt.
3. Most of the roof covering could not be inspected from grade. Recommend this be done before rehabilitation is attempted.
4. Interior of garage not available for inspection. Repair per applicable codes.

This is a registered vacant building. In order to sell or reoccupy this building, all deficiencies listed on this code compliance report must be corrected in accordance with the Minimum Housing Standards of the St. Paul Legislative Code (Chapter 34) and all required permits must receive final approval within six (6) months of the date of this report. One (1) six-month time extension may be requested by the owner and will be considered if it can be shown that the code compliance work is proceeding and is more than fifty (50) percent complete in accordance with Legislative Code Section 33.03(f).

You may file an appeal to this notice by contacting the City Clerk's Office at 651-266-8688. Any appeal must be made in writing within 10 days of this notice. (You must submit a copy of this notice when you appeal, and pay a filing fee.)

Re: 614 Edmund Ave  
May 04, 2016  
Page 8

If you have any questions regarding this inspection report, please contact Jim Seeger between 7:30 - 9:00 AM at 651-266-9046 or leave a voice mail message.

Sincerely,

James L. Seeger  
Code Compliance Officer  
Department of Safety and Inspections  
City of Saint Paul  
375 Jackson Street, Suite 220  
Saint Paul MN 55101  
Phone: 651-266-9046  
Email: [jim.seeger@ci.stpaul.mn.us](mailto:jim.seeger@ci.stpaul.mn.us)

Attachments